



Approve Planning Permission

TOWN AND COUNTRY PLANNING ACT 1990

To:

Mr John Skelton
Skelton Consultancy
31 Stockton Lane
York
YO31 1BP

Application at: 3 Patrick Pool York YO1 8BB
For: Change of use from retail (use class A1) to mixed use restaurant/cafe and drinking establishment
By: Mr John Skelton, Chapter House Developments
Application Ref No: 16/00494/FUL
Application Received on: 4 March 2016

CONDITIONS OF APPROVAL:

1 The development shall be begun not later than the expiration of three years from the date of this permission.

Reason: To ensure compliance with Sections 91 to 93 and Section 56 of the Town and Country Planning Act 1990 as amended by section 51 of the Compulsory Purchase Act 2004.

2 The development hereby permitted shall be carried out in accordance with the following plans:-

Location Plan received 26.2.2016
Dwg No: CHD/PP/02A (Proposed A3 Plan) received 3.3.2016

Reason: For the avoidance of doubt and to ensure that the development is carried out only as approved by the Local Planning Authority.

3 No development shall take place until a detailed scheme of noise insulation measures for the ground floor A3/A4 use has been submitted to and been approved in writing by the Local Planning Authority. The scheme of noise insulation measures shall be prepared by a suitably qualified consultant/engineer and shall take into account the provisions of BS 8233:2014 "Sound Insulation and Noise Insulations for Buildings - Code of Practice". The approved scheme shall be implemented prior to the commencement of the use and be permanently retained thereafter.

Reason: In order to safeguard the amenities of adjoining residential occupiers and the details are needed prior to the start of work so that measures can be incorporated into the build.

4 Details of all machinery, plant and equipment to be installed in or located on the use hereby permitted, which is audible at the boundaries of the nearest residential properties when in use, shall be submitted to the local planning authority for approval. These details shall average sound levels (LAeq), octave band noise levels and any proposed noise mitigation measures. All such approved machinery, plant and equipment shall not be used on the site except in accordance with the prior written approval of the local planning authority. The machinery, plant or equipment and any approved noise mitigation measures shall be fully implemented and operational before the proposed use first opens and shall be appropriately maintained thereafter.

Note: The combined rating level of any building service noise associated with plant or equipment at the site should not exceed the background noise level at 1 metre from the nearest noise sensitive facades when assessed in accordance with BS4142: 2014, inclusive of any acoustic feature corrections associated with tonal, impulsive, distinctive or intermittent characteristics.

Note that any external plant not shown on the approved plans will require planning permission.

Reason: To protect the amenity of local residents

5 The use hereby permitted shall not be open to customers outside the following times:

Mondays to Sundays 08:00 to 23:00 hours.

Reason: In the interests of the amenity of future occupants and those of surrounding premises.

6 Upon completion of the development, delivery vehicles and waste removal vehicles to the development shall be confined to the following hours:

Monday to Friday 08:00 to 18:00 hours

Saturday 09:00 to 13:00 hours and not at all on Sundays and Bank Holidays.

Reason: In the interests of the amenity of future occupants and those of surrounding premises.

7 There shall be adequate facilities for the treatment and extraction of cooking odours. Details of the extraction plant or machinery and any filtration system required shall be submitted to the local planning authority for written approval prior to the development commencing. Once approved it shall be installed and fully operational before the proposed use first opens and shall be appropriately maintained and serviced thereafter in accordance with manufacturer guidelines.

Note: It is recommended that the applicant refers to the Defra Guidance on the Control of Odour and Noise from Commercial Kitchen Exhaust Systems (January 2005) for further advice on how to comply with this condition. The applicant shall provide information on the location and level of the proposed extraction discharge, the proximity of receptors, size of kitchen or number of covers, and the types of food proposed. A risk assessment in accordance with Annex C of the DEFRA guidance shall then be undertaken to determine the level of odour control required. Details should then be provided on the location and size/capacity of any proposed methods of odour control, such as filters, electrostatic precipitation, carbon filters, ultraviolet light/ozone treatment, or odour neutraliser, and include details on the predicted air flow rates in m³/s throughout the extraction system.

Reason: To protect the amenity of future residents and nearby properties.

8 All electronically amplified music emitted from the premises shall be restricted to background music only and shall not be audible at the nearest noise sensitive facade.

Reason: To protect the amenity of occupants of the nearby properties from noise.

Date: 28 April 2016



M. Slater
Assistant Director (Development Services,

FOR RIGHTS OF APPEAL, SEE OVERLEAF

Notes to Applicant

1. STATEMENT OF THE COUNCIL'S POSITIVE AND PROACTIVE APPROACH

In considering the application, the Local Planning Authority has implemented the requirements set out within the National Planning Policy Framework (paragraphs 186 and 187) in seeking solutions to problems identified during the processing of the application. The Local Planning Authority took the following steps in order to achieve a positive outcome:

- the use of conditions

2. WASTE

Section 34 of the Environmental Protection Act 1990 places a duty of care on all producers of controlled waste, i.e. businesses that produce, store and dispose of rubbish. As part of this duty, waste must be kept under proper control and prevented from escaping. Collection must be arranged through a registered waste carrier. It is unlawful to disposal of commercial waste via the domestic waste collection service.

Adequate arrangements are required for proper management and storage between collections.

Section 47 of the Environmental Protection Act 1990 states that the storage of commercial waste must not cause a nuisance or be detrimental to the local area. Adequate storage and collections must be in place. Where the City of York Council Waste Authority considers that storage and/or disposal are not reasonable, formal notices can be served (Section 47 of the Environmental Protection Act 1990). Storage containers cannot be stored on the highway without prior consent of the Highway Authority of City of York Council.

3. MEANS OF EXTRACTION / SIGNAGE

The applicant should be aware that this application has been considered on the basis of there being no requirement for external extraction beyond a domestic type extract fan. Should a future occupant wish to explore alternative options for extraction, it is recommended that the Local Planning Authority is consulted at an early stage, as planning permission may be required.

Similarly, the applicant should consult with the Local Planning Authority with regard to whether advertisement consent would be required for the display of signs at the property.

Appeals to the Secretary of State

- . If you are aggrieved by the decision of the City Council to attach conditions to the grant of planning permission, then you can appeal to the Secretary of State for the Environment under Section 78 of the Town and Country Planning Act 1990.
- . If you want to appeal, then you must do so within SIX months of the date of this. You must use a form which you can get from The Planning Inspectorate, at Temple Quay House, 2 The Square, Temple Quay, Bristol, BS1 6PN (tel: 0303 444 5433) or which can be downloaded from their web site (<https://www.gov.uk/appeal-planning-inspectorate>).
- . The Secretary of State can allow a longer period for giving notice of an appeal, but he will not normally be prepared to use this power unless there are special circumstances which excuse the delay in giving notice of appeal.
- . The Secretary of State need not consider an appeal if it seems to him that the City Council could not have granted planning permission for the proposed development, or could not have granted it without the conditions it imposed, having regard to the statutory requirements, to the provisions of the Development Order and to any directions given under the Order.
- . In practice, the Secretary of State does not refuse to consider appeals solely because the City Council based its decision on a direction given by him.

Purchase Notices

- . If either the City Council or the Secretary of State for the Environment refuses permission to develop land or grants it subject to conditions, the owner may claim that he can neither put the land to a reasonably beneficial use in its existing state, nor can he render the land capable of a reasonably beneficial use by the carrying out of any development which has been or would be permitted.
- . In these circumstances, the owner may serve a purchase notice on the City Council to purchase his interest in the land in accordance with the provisions of Part VI of the Town and Country Planning Act 1990.

Compensation

- . In certain circumstances, compensation may be claimed from the City Council if permission is refused or granted subject to conditions by the Secretary of State on appeal or on reference of the application to him.
- . These circumstances are set out in Section 120 and related provisions of the Town and Country Planning Act 1990.

Note

This permission does not absolve you from the need to obtain approval under the Building Regulations, or to obtain approval under any other Bye-Laws, Local Acts, Orders, Regulations and statutory provision in force, and no part of the proposed development should be commenced until such further approval has been obtained.