



Symbol Key:

Quantity	Symbol	Description
6		Proposed 6 metre raise and lower planted root steel lighting column with post top mounted Holophane Syracuse 70W SON-T lantern, ref: QSS70XT (Default C7) mounted at 5° inclination.

Notes:

1. Lighting designed to achieve a 0.6 lux min lighting class in accordance with BS EN 13201 and the recommendations of BS 5489.
2. Maintenance Factor based on a 3 year bulk lamp change and clean regime in a medium pollution category environment using an IP6X lantern in accordance with Table D.1 of BS 5489.
3. All proposed columns are to have new DNO services.  
Column numbering key:  
N - Denotes new DNO service.  
R+L - Denotes raise and lower column.

Owen Williams  
Part of Amey plc



			DESIGN	LT	DRAWN	LT	CHECKED
A	Original	19/11/07	DATE	BY	SCALE@A4	1:1000	DATE
	Revision				APPROVED		DRAWING No.
PROJECT/DRAWING TITLE						AIS/OW/W/036	
HOWE HILL ROAD SNICKET TO POPPLETON ROAD, YORK.						CITY OF YORK COUNCIL	