

N M Hutchinson MSc; MA;BA(Hons); MI.Fire E.
Chief Fire Officer/Chief Executive

Your Reference:

My Reference:

00123066 01 hah

York Fire Station
Clifford Street
York
YO1 9RD

When telephoning please ask for:

Miss Hilary Hustwick

Telephone: 01904 625272

Fax:

9 May 2008

Dear Sir/Madam

LICENSING ACT 2003

Applicant/Licensee: Whitbread Group Plc

Premises: Premier Lodge Blossom Street York YO24 1AJ

I refer to the recent application under the above Act for a licence

The Fire Authority wish to make representations on the grounds of Public Safety.


The sliding door entrance to the lobby area of the premier lodge should be on a fail safe device on actuation of the fire alarm system.

The occupancy figure for the premises should not exceed 400 persons

The premises are subject to a risk based inspection regime, the frequency of which is determined by the Fire Authority. If, following an inspection the Fire authority have concerns regarding Public Safety, these will be reported upon.

Should you wish to discuss any item in this report please contact myself at the above address.

Yours faithfully,



(On behalf of the North Yorkshire Fire and Rescue Authority)

Licensing Department
City of York Council
9 St Leonards Place
Exhibition Square
York

RECEIVED
12 MAY 2008