



North Yorkshire  
**FIRE & RESCUE SERVICE**

**N M Hutchinson Msc; MA; BA(Hons) MI. Fire E.**  
Chief Fire Officer/Chief Executive

08 JUL 2008

Your Reference:

**Area Fire Safety Manager  
Clifford Street  
YORK  
North Yorkshire  
YO1 9RD**

My Reference: 00301369

When telephoning  
please ask for: Miss Hilary Hustwick

Telephone: 01904 625272  
Fax: 01904 620732

Dear Sir


**RE: The Duchess 7 The Stonebow York YO1 7NP**

**Regulatory Reform (Fire Safety) Order 2005**

Thank you for your telephone call I can confirm that the Fire Authority have no concerns with the availability of the shared final fire exit leading from the rear of the above premises into Stonebow. This Door is fitted with a push bar to open device which is not locked at anytime from the inside.

Should you wish to discuss any item in this report please contact myself at the above address.

Yours faithfully



Fire Safety Officer

Matthew Tunstall  
The Duchess  
7 The Stonebow  
York  
YO17NP