



RAMLI FIRE LTD
 Tel 07736321387
 ramlifireconsultancy@ramlifire.co.uk
 www.ramlifire.co.uk

Licensing October 2018
 61 Lawrence Street
 York

- New licensed area shown in red to be added to existing Licence
 - Extinguisher - wet chemical
 - Extinguisher - water
 - Extinguisher - carbon dioxide
 - Fire blanket
 - Fire alarm sounder
 - Manual break glass point
 - Detector - smoke
 - Detector - heat
 - Fire alarm indicator panel
 - Notice - Fire exit
 - Illuminated exit notice
 - Emergency light
 - Notice - Push Bar To Open
 - Push pad
 - Notice - fire exit keep clear
 - Notice - fire door keep shut
 - Notice - fire action
- This plan should be read in conjunction with the risk assessment and is not to scale

Fire Alarm
 L3 linked to smoke detectors in flat stair enclosure and heat detector in each flat entrance and kitchen